

 	<h2>Technical Guideline</h2>	Number	01e
FAIR-CC	<h2>Compressed Air</h2>	Status	31.5.11

Compressed Air will be made available centrally at well defined places in the buildings.
 The pressure at the extraction point is between 5 and 7 bar.
 The quality of the air complies with ISO 8573-1 Class 1.3.1
 The "Drucktaupunkt" of the air is -25⁰ C
 The dew-point of the compressed air is -25°C
 longest distance between connection points for not permanently used connections is 20 m
 longest distance between connection points for permanently used connections is 20 m